



QUALITY CONTROL DISTRICT LABORATORY

KERALA WATER AUTHORITY

THIRUVALLA, PATHANAMTHITTA

Telephone No. 0469 2600833. Email : aeqcdltvla@gmail.com

TEST REPORT

Report No: 797/TVLA/02/2024(NA) Date: 29.02.2024

Customer Name & Address CITADEL RESIDENTIAL SCHOOL C/O THE PRINCIPAL ETTICHUVADU P. O	1. Date of Payment Received	27.02.2024
	2. Date of Sample Received	27.02.2024
	3. Time of Sampling	4.00 pm
	4. Sampling done by	CUSTOMER
	5. Sample Code	2024/QC/TVLA/T0798
	6. Source of Sample	POND
	7. Sampling Method	Not Applicable
	8. Sample Quantity	1 LITRE
	9. Test performing dates	From: 27.02.2024 To: 27.02.2024

Sl. No	Characteristics	Unit	Test Method	Maximum acceptable limits as per IS 10500-2012	Limit of Quantification (LOQ)	Result
1	pH at 25°C		IS 3025(part 11)-2022	6.5-8.5	2	6.91


Remarks:-

NB:- The results stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory. Samples will be retained only for 7 days after completion of analysis.

Verified By

Name: Nisha V

Analyst



Authorized by

Name: Deepthy Gopinath

Technical Manager

Page 1/1
** End of Report



QUALITY CONTROL DISTRICT LABORATORY

KERALA WATER AUTHORITY

THIRUVALLA, PATHANAMTHITTA

Telephone No. 0469 2600833. Email : aeqcdltvla@gmail.com

TEST REPORT

Report No:797/TVLA/02/2024(MB)

Date: 29.02.2024

Customer Name & Address

CITADEL RESIDENTIAL SCHOOL
C/O THE PRINCIPAL
ETTICHUVADU P. O


1. Date of Payment Received	27.02.2024
2. Date of Sample Received	27.02.2024
3. Time of Sampling	4.00 pm
4. Sampling done by	CUSTOMER
5. Sample Code	2024/QC/TVLA/T0798
6. Source of Sample	POND
7. Sampling Method	Not Applicable
8. Sample Quantity	200 ml
9. Test performing dates	From: 27.02.2024 To: 28.02.2024

BACTERIOLOGICAL ANALYSIS

Sl. No	Parameters	Acceptable limits as per IS 10500 – 2012	Test Method	Result
1	Total Coliforms	Shall not be detected/100 ml	IS 15185 – 2016	ABSENT
2	E-coli	Shall not be detected/100 ml	IS 15185 – 2016	ABSENT

Remarks: -

NB: -The results stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.



Name: Remya G

Bacteriologist

Page 1/1

** End of Report **